

CITY OF NORTH LAS VEGAS

INTEROFFICE MEMORANDUM

To: Robert Eastman, Planning Manager, Land Development & Community Services
From: Duane McNelly, Land Development Coordinator, Department of Public Works
Subject: ZN-15-2020 **Lone Mountain Allen**
Date: April 21, 2022

In addition to the requirement to comply with the *City of North Las Vegas Municipal Code – Titles 15 and 16, NRS 278* and accepted *Clark County Area Uniform Standard Drawings*, the Department of Public Works recommends the following conditions of approval:

1. Property walls shall not be constructed within the easement granted to Nevada Power for the existing run of poles along the north property line between Lots 8-19.
2. A five foot wide public utility easement is required adjacent to all streets. Regarding the entrance street on Lone Mountain Road between Lots 5 & 6, the property wall cannot be located within this easement area; this is applicable in every corner / side lot location.
3. All known geologic hazards shall be shown on the preliminary development plan, tentative map and the civil improvement plans. Geological hazards such as fault lines or fissures affecting residential structures may substantially alter the tentative map layout and require the submission of a revised tentative map which must be approved by the City prior to final approval of the civil improvement plans. The footprint of proposed structures shall be plotted on all lots impacted by faults and/or fissures and a minimum width of five (5) feet shall be provided from the edge of any proposed structure to the nearest fault and/or fissure
4. Approval of a drainage study is required prior to submittal of the civil improvement plans.
5. Proposed residential driveway slopes shall not exceed twelve percent (12%).
6. All common elements shall be labeled and are to be maintained by the Home Owners' Maintenance Association.
7. The street names shall be in accordance with the North Las Vegas Street Naming and Address Assignment Standards, and must be approved by the City of Las Vegas Central Fire Alarm Office.
8. Approval of a traffic study is required prior to submittal of the civil improvement plans. Please contact Traffic Engineering at 633-2676 to request a scope. A queuing analysis may be required.
9. All driveway geometrics shall be in compliance with the *Uniform Standard Drawings for Public Works' Construction Off-Site Improvements* Drawing Number 222.1.

10. The size and number of access points and their locations are subject to review and approval by the City of North Las Vegas Traffic Engineer and must meet the standards set forth in *North Las Vegas Municipal Code* section 17.24.040. Conformance may require modifications to the site.
11. Right-of-way dedication for a RTC bus turn-out is required on Lone Mountain Road near Allen Lane per the *Uniform Standard Drawings for Public Works' Construction Off-Site Improvements* Drawing Number 234.1.
12. Right-of-way dedication for a RTC bus turn-out is required on Allen Lane near Lone Mountain Road per the *Uniform Standard Drawings for Public Works' Construction Off-Site Improvements* Drawing Number 234.1.
13. Dedication and construction of the following streets and/or half streets is required per the *Master Plan of Streets and Highways* and/or *City of North Las Vegas Municipal Code* section 16.24.100:
 - Lone Mountain Road
 - Allen Lane
 - Kenny Way
 - Verde Way
 - Willis Street
14. Half street improvements are required along the frontage of the City of North Las Vegas parcel (APN 12432401004).
15. A raised median shall be installed within Lone Mountain Road.
16. Standard public streetlights are prohibited within the development, along the internal residential streets. However, carriage lights or small residential lamp posts are allowed and encouraged.
17. All Nevada Energy easements, appurtenances, lines and poles must be shown and shall be located entirely within the perimeter landscape area of this development. Distribution lines, existing or proposed, shall be placed underground if impacted by the proposed development of the parcel or if the pole impedes upon the proper ADA clearances for sidewalk. Under no circumstances will new down guy wires be permitted.

For information only:

- This project shall comply with the General Provisions and Conditions of the *City of North Las Vegas Water Service Rules and Regulations* and the *Design and Construction Standards for Wastewater Collection Systems*.

- Submittal of a Hydraulic Analysis per the *Uniform Design and Construction Standards (UDACS) for Potable Water Systems* is required and will be subject to the review and approval of the Utilities Department.

For more information regarding the land development process and other associated requirements in the City of North Las Vegas, please visit the City's website and find the **Land Development Guide**:
<http://www.cityofnorthlasvegas.com/Departments/PublicWorks/PublicWorks.shtm>.

Duane McNelly, Land Development Coordinator
Department of Public Works